

Questions & Answers

Issued: October 31, 2011

RFP #12-010-16 ELEVATOR MODERNIZATION

TO ALL PROSPECTIVE BIDDERS:

**The following questions were submitted by potential vendors
Our answers are listed in red below:**

1. Sheet G2, Door Schedule, General Note: states that the contractor is to install “owner furnished hardware.” But under Remarks is says for the contractor to “provide heavy duty hardware.” Is the door hardware owner provided or contractor provided? **Sheet G2, Door Schedule/ General: All door hardware shall be new and be furnished and installed by contractor.**
2. If the hardware is contractor provided than is there any new hardware required for door D142. **Door D142 shall have the same hardware requirements as D406.**
3. Where would the tempered glass, closer and 10” SS kick plate be used (this is under the General Note). **Sheet G2/Door Schedule/General: Delete the note, “PROVIDE TEMPERED GLAZING IN BEVELED FRAME, SIZE AS SHOWN. 10” SS KICK PLATE ON BOTH SIDES OF DOOR.”**
4. Is earthquake and flood insurance required for this project? **Earthquake and flood insurance is not required for this project.**
5. What time are bids due and how many copies are to be submitted? **Bids are due by 4:00 PM, November 4, 2011 and an original and six copies are required.**