Shelby County Government

MARK H. LUTTRELL, JR.
MAYOR

February 5, 2013

To Whom It May Concern

RE: RFP # 13-001-33, Exterior Resurfacing 157 Poplar Avenue

ADDENDUM # 2

THE LISTED CORRECTIONS SHOULD BE INCORPORATED INTO THE PLANS/SPECIFICATIONS. ALL BIDDERS ARE REQUIRED TO INDICATE ON THE SHELBY COUNTY BID FORM THE RECEIPT OF THIS INFORMATION BY NOTING THE ADDENDA # 2.

General Notes

None these addenda

Changes to the Drawings

None these addenda

Changes to the Specifications

1. Section **01 22 00 UNIT PRICES** Part 3 –EXECUTION

   Remove the existing section
   "3.01 UNIT PRICE SCHEDULE" and replace it with the following;

A. Unit Price No. 1 – Patch Repair

Refer to Detail B3 / Sheet S1.1, **Type A**. This unit price includes costs per square foot for the patch repair. Unit price shall include work associated with cleaning of rebar, concrete removal, application of bonding agent, application of patch material, labor etc, to repair existing damage. Quantities required above those listed on sheet S1.1 will be an additional scope of work for which the contractor will be compensated. Quantities required below those listed in Detail B3 will be deducted from the contractor's compensation.

Cost per square foot of Patch Repair, Type A - $ _____

B. Unit Price No. 2 – Patch Repair

Refer to Detail B3 / Sheet S1.1, **Type B**. This unit price includes costs per square foot for the patch repair agent. Quantities required above those listed on sheet S1.1 will be an additional scope of work for which the contractor will be compensated. Quantities required below those listed in Detail B3 will be deducted from the contractor's compensation.

Cost per square foot of Patch repair, Type B - $ _____

C. Unit Price No. 3 – Coating Agent

Refer to Detail B3 / Sheet S1.1, **Type C**. This unit price includes costs per square foot for the coating agent. Quantities required above those listed on sheet S1.1 will be an additional scope of work for which the contractor will be compensated. Quantities required below those listed in Detail B3 will be deducted from the contractor's compensation.

Cost per square foot of Coating Agent, Type C - $ _____

D. Unit Price No. 4 – Aluminum Trim

Refer to detail B3, Sheet A4.1 – The contractor, in the base bid is to include provision to provide and install 25 pieces of rectangular flat aluminum at window heads to cover joints in the window head framing where it has failed. This unit price is to provide a cost to provide and install additional aluminum trim pieces in the vent more than 25 are required.

Cost per unit for Aluminum Trim - $ _____

2. Section **07 72 00 GUARD RAIL SYSTEM**

PART 1 GENERAL

1.01 SUMMARY

Add the following paragraph;

"C. The roof edge protection system is to mount on the existing roof and be supported by counterweights as designed by the manufacturer. The system is not to be installed by penetrating the roof membrane, the parapet or the exterior wall of the building."

Thank you,

Nelson Fowler, Manager A
Shelby County Government
901-222-2251

Cc: Diep Tran, Support Services
Arthur Yeates, Askew Hargraves Harcourt & Associates
RFP File 13-001-33