



# Shelby County Government

MARK H. LUTTRELL, JR.  
MAYOR

March 12, 2014

To Whom It May Concern:

RE: RFP 14-002-47, Installation of Sprinkler System, 980A Nixon Avenue

## Addendum No. 1

Please note the following:

1. Refer to drawing FA-1:
    - a) Circuit's referenced coming from panel "A" shall be fed from panel "RC" located in the lower right hand corner of the archives space.
    - b) All fire alarm wiring located above 10'-0" can be open wiring. All fire alarm wiring located below 10'-0" shall be in EMT conduit.
- End of Addendum No. 1

If you have any questions or concerns, please e-mail me at [nelson.fowler@shelbycountyttn.gov](mailto:nelson.fowler@shelbycountyttn.gov).

Thank you,

Nelson Fowler, Manager A  
Shelby County Government  
901-222-2250

Cc: Diep Tran, Support Services  
Dave Canup, Canup Engineering, Inc.  
RFP File 14-002-47