

**SHELBY COUNTYVERNMENT  
SHELBY COUNTY ARCHIVES  
SPRINKLER ADDITION  
980A NIXON DRIVE  
MEMPHIS, TN 38134  
RFP 14-002-47-A  
Addendum No. 1  
May 12, 2014**

**n**

1. Refer to drawing Fire Protection Drawings:
  - a. Remove the wall mounted fire department connection (FDC) from the north side of the building. Extend a 4" pipe from the riser connection to below grade in the same ditch as the fire main to within 100 ft. of the nearest fire hydrant and provide a remote fire department connection. Coordinate exact location with existing site utilities, grades, structure, etc.

End of Addendum No. 1