



Shelby County Government

MARK H. LUTTRELL, JR.
MAYOR

February 13, 2015

To Whom It May Concern:

RE: RFP # 15-001-23, Replacement of Fuel Storage Tanks, 6411 Haley Road

ADDENDUM # 1

The due date for this project is being extended from 4:00 PM Friday February 20, 2015 to 4:00 PM Friday, February 27, 2015.

The last day to answer questions is being extended from 12:00 PM Friday, February 13, 2015 to 12:00 PM Friday, February 20, 2015.

Below is clarification to questions asked at our pre-bid conference:

1. The existing tanks are single wall steel with steel pipes.
2. The Veeter Root system will be completely replaced with a Veeter Root 350.
3. The average two week usage of fuel for this facility is:
Unleaded = 16,958 gals/2 wks
Diesel = 5,448 gals/ 2 wks
4. A new overflow alarm must be installed.
5. The contractor must mark utility locations at the site.

Addendum # 2 will be issued on or before February 19, 2015 to answer all remaining questions from our pre-bid conference.

If you have any questions or concerns, please e-mail me at nelson.fowler@shelbycountyttn.gov.

Thank you,

Nelson Fowler, Manager A
Shelby County Government

Cc: Ryan Hertter, Innovative Engineering Services
Diep Tran, Support Services
RFP File 15-001-23