

**QUESTIONS & ANSWERS**  
**RFP # 15-007-08**  
**ROOF REPLACEMENT**  
**1362 MISSISSIPPI BLVD.**

Good evening,

Could you clear up the following:

1.5 CONTRACTS

B. Contractors Qualification:

Can only a Roofing Contractor bid on this RFP# 15-007-08?

I currently hold a State License and meet all of the other qualifications.

Yes, in addition to TN BC-21 classification license holders we will allow a Classification "BC-B" TN licensed general contractor to bid on this job only if they are certified by the roofing product manufacturer for installation of one of the specified roofing systems.

---

You bid request was misplaced in our office and I just got it this morning.

I would like to bid on this project.

Could you please send me the sign in sheet and pre-bid meeting minutes.

I would also like to know when I can visit site for an inspection.

I have attached the sign-in sheet from the pre-bid conference but cannot provide you with minutes of the meeting since none were taken. If you wish to visit the work site, please contact Steve Graves at 901-222-2525.

---

I would like to respectfully request your consideration of Sikaplan 60 mil mechanically fastened Thermoplastic Polyvinyl-Chloride (PVC) Roofing System with a 20 year warranty, as a Substitution on the Correction Re Entry Program bids due August 15th.

Sika Sarnafil manufactures thermoplastic PVC membranes that are energy-efficient and meet Energy

Star and LEED criteria for low slope and steep slope applications.

I have attached the Substitution Request Form, a Sikaplan Guide Spec, a Sikaplan Product Data Sheet and other pertinent data, as it pertains to the project specifications. Our

Sikaplan 60 mil mechanically fastened membrane is Energy Star Rated and meets ASTM requirements. Sikaplan 60 mil is polyester reinforced.

No we cannot substitute a PVC for a TPO roof system.

---

Will the coping that is on the building be reused?

No. We plan to issue an addendum to request new coping.  
Specifications will be in the addendum

---

**Please Note: Addendum # 1 posted to our web site Tuesday, August 12, 2014.**