



# Shelby County Tennessee

Mark H. Luttrell, Jr., Mayor

## Questions & Answers

*Issued: March 14, 2016*

**RFP 16-002-46**

### Fire Fleet Maintenance Facility

#### TO ALL PROSPECTIVE BIDDERS:

The following questions were submitted by potential vendors. Our answers are listed in *red* below:

#### Questions:

1. Question: What is the loading requirement of the Gantry Beam located in Big Bay 8 (Gantry)?

The Gantry Beam to be provided in Big Bay 8 is to be able to support a load of 6,000 pounds at any point along the length of the beam. The Gantry Beam along with all of the Gantry Beam supports and bracing are to be furnished as part of the Work.