

QUESTIONS & ANSWERS
RFP # 16-009-24
JUVENILE COURT SPRINKLER SYSTEM
616 ADAMS AVENUE

Question 1:

Our plumber wanted clarification on whether or not there are post-tension cables in the areas that are to be core drilled.

Answer 1:

The original structural drawings do not indicate post-tension cables. However, the floor drain locations are approximate and can be shifted slightly to miss any such issues if needed. There appear to be several sleeved and core drilled locations in the slabs in various areas, so this should not be an issue.