Shelby County Government

MARK H. LUTTRELL, JR.
MAYOR

May 11, 2015

TO ALL BIDDERS:

RE: **Addendum No. 1 to RFQ 15-004-43**
Cotton Creek Gravity Sewer System

Please see the attachments to this Addendum No. 1 as follows:

1. Engineer's Report Phase 1
2. Engineer's Report Phase 2
3. Sewer As-Built Plan April 2011

Please note the following revisions and clarifications to the above referenced project:

Question: Will there be any service connections?

Answer: No. The sewer services will be stubbed at the right-of-way line.

Question: Will there be a NEPA study required for this project?

Answer: Yes.

Question: What source of funding is used for this project?

Answer: This project is funded with County funds, however, we are including a NEPA document as part of the project so we can qualify for Federal or State funds in the future.

Question: How many homes are currently on the low pressure sewer system (LPSS)?

Answer: There are 93 homes on the LPSS.

Question: Where are the sewer service connections to be located?

Answer: We will provide the LPSS design plans to assist the designer with the most suitable layout for the gravity system and sewer service stub outs.

Question: How is the sewer system currently being sent to Collierville?

6449 Haley Road • Memphis, TN 38134 • 901-222-7705 • Fax 901-222-7728
www.shelbycountytn.gov

Answer: The LPSS drains into a lift station north of the intersection of Collierville-Arlington Road and Raleigh Lagrange Road. The manhole is on the east side of Collierville-Arlington Road. The sewer from the manhole is then pumped to the Shelton Road sewer plant.

Question: Will the plans be reviewed by Collierville?

Answer: Yes.

If you have any questions, please contact Mr. Nelson Fowler at 222-2250.

Sincerely,

James M. Crook

James M. Crook E.I.

Shelby County Roads, Bridges & Engineering Department

Cc: Darren Sanders, P.E.

Nelson Fowler

File