



Shelby County Government

MARK H. LUTTRELL, JR.
MAYOR

May 5, 2015

TO ALL BIDDERS:

RE: **Addendum No. 1 to Sealed Bid # I-000322**
Health Department Parking Lot Project

Please note the following revisions and clarifications to the above referenced project:

1. **Question:** Will the successful bidder have to meet the slope compliance with ADA requirements?

Answer: The County will coordinate with the successful bidder to reconfigure the parking lot striping layout for ADA compliance.

2. **Question:** What is the thickness of the asphalt?

Answer: The asphalt thickness will be one and a half inches.

3. Please note that the quantities for asphalt includes the circle drive on North Dunlap.

If you have any questions, please contact Mr. Nelson Fowler at 222-2250.

Sincerely,

James M. Crook E.I.

Shelby County Roads, Bridges & Engineering Department

Cc: Darren Sanders, P.E.

Nelson Fowler

File