

April 16,2014

Mr. Eddy Bouzeid
Tennessee Department of Environment & Conservation
Division of Water Pollution Control
8383 Wolf Lake Drive
Memphis, TN 38133

Re: Bolton Estates Subdivision Wastewater Treatment Facility
SOP – 04050
2014 1st Quarter Operating Report

Dear Mr. Bouzeid:

For the first quarter of 2014, Ammonia and BOD₅ were sampled on March 26,2014 and taken to Cornerstone Laboratories for analysis. The results were 0.6 mg/L for Ammonia and 22 mg/L for BOD₅.

The average flow value for January, February and March was approximately 5210 gallons per day or about 0.005 MGD.

Please contact me with any questions at darren.sanders@shelbycountyttn.gov or (901) 222-7705.

Sincerely,

Darren Sanders, P.E.
Administrator
Operator #3431