



Shelby County Government

MARK H. LUTRELL, JR.
MAYOR

July 15, 2014

Mr. Eddy Bouzeid
Tennessee Department of Environment & Conservation
Division of Water Pollution Control
8383 Wolf Lake Drive
Memphis, TN 38133

Re: Bolton Estates Subdivision Wastewater Treatment Facility
SOP – 04050
2014 2nd Quarter Operating Report

Dear Mr. Bouzeid:

For the second quarter of 2014, Ammonia and BOD₅ were sampled on June 27, 2014 and taken to Cornerstone Laboratories for analysis. The results were 0.9 mg/L for Ammonia and 43 mg/L for BOD₅.

The average flow value for April, May and June was approximately 6440 gallons per day or about 0.006 MGD.

Please contact me with any questions at randy.crawford@shelbycountyttn.gov or (901) 222-7745 or (901) 508-5782

Sincerely,

Randy Crawford

Operator #14279